



END VIEW W/OUT SUPPORTS

2) 4-1-04 PROOF TEST.
 NOTE: 1) HYDRO @ 240 PSIG. MIN.

HEADS	.182" SA-455 2:1 S.E.	ES-36-400-H	REV. 9-15-04
	JOGGLE		DATE: 9-27-89
SHELL	.164" SA-414-G	FOR: HANSON STANDARD	
		HORIZ. HOT WATER TANK	
M.A.W.P. 160 PSIG. @ 180 °F		SURFACE AREA = 82.2 SQ. FT.	
ASME SECTION IV 2001 ADD. 2003		INSIDE: EPOXY LINED	
X-RAY: RT-NO/H.L.W.		OUTSIDE: PRIME	
GALLONS: 400 WT. 730 LBS.		CAD-"B" UNDER "STD"-SERIES	
SERIAL NO.		BY: E.S.	SCALE: 3/4"=12"
		ROY E. HANSON JR. MFG.	
		1924 COMPTON AVE. LOS ANGELES, CA 90011	