



VIEW W/OUT SUPPORTS

2) 4-1-04 PROOF TEST.
 NOTE: 1) HYDRO @ 240 PSIG. MIN.

HEADS	.205" SA-455 2:1 S.E.	ES-42-534-H	REV. 9-16-04
	JOGGLE		DATE: 10-2-89
SHELL	.175" SA-414-G	FOR: HANSON STANDARD	
		HORIZ. HOT WATER TANK	
		SURFACE AREA = 94.1 SQ. FT.	
	M.A.W.P. 160 PSIG. @ 180 °F	INSIDE: EPOXY LINED	
		OUTSIDE: PRIME	
	ASME. SECTION IV 2001 ADD 2003	CAD-"B" UNDER "STD"-SERIES	
	X-RAY: RT-NO / H.L.W.	BY: E.S.	SCALE: 3/4"=12"
	GALLONS: 534	WT. 895 LBS.	ROY E. HANSON JR. MFG. 1924 COMPTON AVE. LOS ANGELES, CA 90011
	SERIAL NO.		
	N.B.		